

Tarmac Holdings Limited Site Address:  West Cornforth Ferryhill DL17 9EY	24
	Aggregates for Mortar
	0/2MM YELLOW BUILDING SAND CAT3
	Thrislington West 13859

BS EN 13139 - 2002

**GENERAL**

Particle size	d/D	0/2mm
	Category	FP
	Grading Tolerance category	NR
Cleanliness	Fines content F	Category 3
Particle density	Density - Mg/m <sup>3</sup>	2.60
Water absorption	WA	0.4
Petrographic description	Petrographic composition	SILICA SAND
Composition/content	Chlorides C	<0.001
	% Acid soluble Sulfate AS1,0	AS 0,2
	Total sulfur S	0,1% S
	Lightweight contaminators	<0,5% by Mass; Pass
% CO <sub>2</sub>		0.1
Volume stability	Drying Shrinkage %WS	PASS <0.040% WS

This document relates to material supplied	
Plant code (plant name)	B639 (Thrislington West)
Material code (material description)	110S02F3BY (0/2MM YELLOW BUILDING SAND CAT3)
Date	25/06/2024
Time	12:00